



# National Center for Mental Health

## SUPPLEMENTAL BID BULLETIN

### ADDENDUM NO. 1

#### Public Bidding for the Supply, Delivery, Installation, Testing and Commissioning of Solar Power System at Administration Building and Pavilion 2 CY 2024

This Supplemental Bid Bulletin No. 1 dated **October 21, 2024** is issued to clarify, modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents.

#### A. Amendments / Clarifications:

FROM	TO
<p>ON LIST OF ITEMS / TECHNICAL SPECIFICATIONS</p> <p>SPECIFICATIONS:</p> <p>III. POWER INVERTER ((Administration Building)</p> <ul style="list-style-type: none"> <li>2-3 units of 10,000W – 15,000W Grid-tie</li> </ul> <p><u>Recommend Specification:</u></p> <ul style="list-style-type: none"> <li>➤ "As per our survey single phase installation will have around 6 grid tied inverters. It will contradict the requirements of 2-3 inverters per system design. May we request a copy of single line diagram and roof layout."</li> </ul>	<p>ON LIST OF ITEMS / TECHNICAL SPECIFICATIONS</p> <p>SPECIFICATIONS:</p> <p>III. POWER INVERTER ((Administration Building)</p> <ul style="list-style-type: none"> <li>2-3 units of 10,000W – 15,000W Grid-tie</li> </ul> <p><u>Response:</u></p> <ul style="list-style-type: none"> <li>➤ "The Procuring Entity shall stick to the requirement for inverters for single phase (Administration Building) – 2 units of 15KW Inverter or 3 Units of 10KW Inverter. We encourage actual site inspection to evaluate the electrical and roofing systems of the buildings due to absence of the requested documents."</li> </ul>
<p><u>Other Queries:</u></p> <ul style="list-style-type: none"> <li>➤ 1. "Pavilion 2 is 30 kw solar system?"</li> <li>2. "Admin Bldg. is 30 kw also?"</li> </ul>	<p><u>Response:</u></p> <ul style="list-style-type: none"> <li>➤ "Yes. Both the Pavilion 2 and the Administration Building require 30KW."</li> </ul>
<ul style="list-style-type: none"> <li>➤ "Will a solar PV power system project worth over Php 5 Million under a Build-Own-Operate-Transfer (BOOT) Agreement be acceptable as SLCC?"</li> </ul>	<ul style="list-style-type: none"> <li>➤ "Yes. Please refer to Section 23.4.1.3 of Republic Act. No. 9184 and consider the requirements stipulated in the bidding documents of this project."</li> </ul>

#### Other Matters:

- Bid Security shall be 120 calendar days from the date of submission and opening of bids.
- Section VII: Technical Specifications - Please write "COMPLY" to indicate that requirements are met.
- Eligibility requirements and technical proposal should be in one folder and financial proposal in a separate folder, with shoelace on top instead of fastener, table of contents and index tabs in words, not numbers.

**"There is no Health without Mental Health"**



- D. *Folder of Eligibility requirements and technical proposal should be placed in one envelope. And folder of Financial proposal should be in another envelope. Both envelopes shall then be placed in one mother envelope marked as "Original Bid"*
- E. Documents should be arranged chronologically according to the checklist issued.
- F. Color code for folders and envelope: **GREEN**
- G. Typographical error must be counter signed by the authorized representative.
- H. All other provisions on the bidding documents which are not affected shall remain in effect.
- I. The deadline for **Submission and Opening of Bids** is scheduled on **October 28, 2024, 9:00 AM**, at the **BAC Conference Room**, National Center for Mental Health Compound, Mandaluyong City.
- J. Any bid submitted after the deadline for submission shall be declared "**LATE**" and shall NOT be accepted.
- K. The BAC shall open the bids immediately after the deadline for submission and receipt of bids.
- L. The onsite installation inspection will be conducted within 10 calendar days upon receipt of Notice of Eligibility.

For the information and guidance of all concerned.

  
**ALDEN C. CUYOS, MD, FPPA, IFAPA**  
Chairperson, BAC for Equipment CY 2024 *q*